

Report No.: ENV/ARL&NERPL/GHY/21-22/WW-01
Date : 27/09/2021

Order No.:
Date :

Report Issued To : **ASSAM ROOFING LIMITED/NORTH EAST ROOFING LIMITED**
Bonda, Narengi, Guwahati – 26 (Assam)

WASTE WATER ANALYSIS RESULTS

Sample Ref. No. : ARL&NERPL/2021/WW-1109/01
Sample Type/Source : STP Treated Water/Outlet of common STP of Assam Roofing Ltd. & North East Roofing Ltd.
Sample Collected By : Representative of Envirocon
Sample Collected On : 11.09.2021
Sample Received On : 12.09.2021
Analysis Protocol : IS 3025

S. No.	Parameters	Results	Units	Limits (As per CPCB)
1.	pH	6.65	--	6.5 – 9.0
2.	Bio-chemical Oxygen Demand (as BOD)	8	mg/l	20
3.	Total Suspended Solids (as TSS)	12	mg/l	<50
4.	Oil & Grease	BDL	mg/l	10
5.	Ammonical Nitrogen (as N)	6.3	mg/l	50
6.	Total Kjeldahl Nitrogen (as NH ₃)	11	mg/l	100
7.	Free Ammonia (as NH ₃)	<0.01	mg/l	5.0
8.	Fecal Coliform (as FC)	230	MPN/100ml	<1000

BDL: Below Detectable Limit



Checked By: Mr. Pankaj Baroi, **ENVIROCON**

NOTE:

- Results reported are valid at the time of and under the prevailing conditions of measurement.
- Results refer only to the particular parameters tested.
- This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi – 786171, Assam.

Core Services: Environmental Monitoring & Data Generation, EIA & EMP, Environmental Audit & Allied Environmental Management jobs
Associate Services: Certification by Competent Person (CIF), NDT, Hydraulic Testing, Chartered Engineer Services etc.