

Sheet3

## Northeast Roofing(P)Ltd.

For the year ended 31.03.2021

| S.No | Raw Material | Qty.(MT) |
|------|--------------|----------|
| 1    | Cement       | 13785.24 |
| 2    | Asbestos     | 2462.48  |
| 3    | Flyash       | 8789.34  |
| 4    | Pulp         | 563.81   |
| V5   | Water        | 7041.88  |
| al   |              | 32642.75 |

Page 1



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE:

- $1. \ Results \, reported \, are \, valid \, at \, the \, time \, of \, and \, under \, the \, prevailing \, conditions \, of \, measurement.$
- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, LO.C.L (AOD) New Market, Digboi 786171, Assam,



Recognised By
Pollution Control Board, Assam

Envirocon Building, I.O.C.L (AOD) New Market P.O.: Digboi, Dist.: Tinsukia, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672 E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/ARL&NERPL/GHY/21-22/WW-01

Date

:27/09/2021

Order No.: Date

Report Issued To:

ASSAM ROOFING LIMITED/NORTH EAST ROOFING LIMITED

Bonda, Narengi, Guwahati - 26 (Assam)

## **WASTE WATER ANALYSIS RESULTS**

Sample Ref. No.

: ARL&NERPL/2021/WW-1109/01

Sample Type/Source

: STP Treated Water/Outlet of common STP of Assam Roofing Ltd. & North East Roofing Ltd.

Sample Collected By

: Representative of Envirocon

Sample Collected On Sample Received On : 11.09.2021 : 12.09.2021

Sample Received On Analysis Protocol

: IS 3025

| S. No. | Parameters                                    | Results | Units     | Limits<br>(As per CPCB) |
|--------|---|---------|-----------|-------------------------|
| 1.     | pH  | 6.65    | -         | 6.5 - 9.0               |
| 2.     | Bio-chemical Oxygen Demand (as BOD)           | 8       | mg/l      | 20                      |
| 3.     | Total Suspended Solids (as TSS)               | 12      | mg/l      | <50                     |
| 4.     | Oil & Grease                                  | BDL     | mg/l      | 10                      |
| 5.     | Ammonical Nitrogen (as N)                     | 6.3     | mg/l      | 50                      |
| 6.     | Total Kjeldahl Nitrogen (as NH <sub>3</sub> ) | 11      | mg/l      | 100                     |
| 7.     | Free Ammonia (as NH3)                         | <0.01   | mg/l      | 5.0                     |
| 8.     | Fecal Coliform (as FC)                        | 230     | MPN/100ml | <1000                   |

BDL: Below Detectable Limit



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE:

- 1. Results reported are valid at the time of and under the prevailing conditions of measurement.
- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, LO.C.L (AOD) New Market, Digboi 786171, Assam.

Core Services: Environmental Monitoring & Data Generation, EIA & EMP, Environmental Audit & Allied Environmental Management jobs
Associate Services: Certification by Competent Person (CIF), NDT, Hydraulic Testing, Chartered Engineer Services etc.